

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7151-0801:153 Page 1 of 1

CATEGORY: Boxes/Pull Stations For Hazardous Locations

LISTEE: Radionics, Div. Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199
Contact: Frank Mioduszewski *(585) 223-4060 Fax (585) 421-4263

DESIGN: Models D468 non-coded, explosion proof, weather proof manual pull stations. Unit consists of a switch and terminal block mounted within an explosion proof enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 120 VAC, 10 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm manual pull station for use with separately listed compatible control units. Suitable for use outdoor and in Class I, Group B, C and D; Class II, Group E, F and G hazardous locations.

XLF: 7151-1039:104

*Rev. 05-31-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager